

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201210
Address: 2924 NW THOREAU DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Monday, March 28, 2022

Corrective Action Required:

1	Miscellaneous Correction	- Driveway inspection pending - All rough inspection pendant - Final grading and sod - Rough inspection inspection pass - submit a back flow certification - Provide cooking appliances - Label all non- GFCI outlets - Land gas trace wire - Poly Gas line above ground , must be marked (Gas) in black. And protection provided from physical damage , protection from UV - Handrail required on steps from pool - Guard required on corner of pool - Complete gutters and down spouts - Provide splash blocks
---	--------------------------	---

Comments: