

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215425
Address: 2031 SW WHEATFIELD CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Eric Sharp	Partial	Monday, March 28, 2022

Corrective Action Required:

1	Misc	Driveway has soft/wet spots that need to be dug out and recompact. 3/25/22 ES
---	------	---

Informational:

2	Misc	Driveway was framed up with aggregate in and compacted. 3/28/22 ES
---	------	--

Comments: