

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20220056  
Address: 2032 NE BLUESTONE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Residential</b>	Khanh Nguyen	Failed	Tuesday, March 29, 2022

Corrective Action Required:

1	Misc	***DEFICIENT EROSION CONTROL INSTALLATION ALONG THE STREET AND ALONG PROPERTY LINE. NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED***  -DIG SOUTH PIERS DOWN TO BEARING SOIL -REMOVE ALL LOOSE DIRT FROM PIER HOLES -THE NORTH PIER IS A 30" DIA PIER
---	------	---

Comments: