

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210103
Address: 2100 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Engineering	Adam Nacke	Failed	Tuesday, March 29, 2022

Corrective Action Required:

1	Miscellaneous Correction	Temporary occupancy - need as built for detention basin, remove silt , also the basin is not draining properly.
		Final occupancy - need vegetation

Comments: