## CITY OF LEE'S SUMMIT **Development Services Department** 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20211575

Address: 131 NW JOSHUA DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

**Occupancy Inspection - Codes** Michael Harkins Failed Tuesday, March 29,

Residential 2022

Corrective Action Required:

Miscellaneous Provide guard (spindles) garage stairs: 2018 IRC R312.1.1 1

> Correction Submit as graded Plot plan Seal top of exterior light fixtures

> > Land sewer tracer wire in a box at grade level

Provide gutters & downspouts

Provide splash blocks

Sump shall discharge 36" from foundation

Provide (2) 3" screws in each exterior door hinge & strike plate

Provide missing spindle guardrail next to fireplace 4" sphere shall not pass

through

Remove dust covers smoke detectors

Basement handrail end shall be returned or shall terminate in newel post

Remove concrete forms back patio near meter can

Seal top of ac disconnect

## **Comments:**