

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211820
Address: 1867 NE PARK RIDGE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Adam Nacke	Passed	Tuesday, March 29, 2022

Informational:
1 Misc 12/30/21 Thursday
Sidewalk forms and materials passed pre-inspection.

Informational:
2 Miscellaneous 3-16-22 AN sidewalk to the left of the driveway was over 2%
Correction

Informational:
3 Misc 3-16-22 AN forms are in place and aggregate is present and compacted. They
fixed part that was over 2%

Informational:
4 Misc Sidewalk looks good and meets ADA spec

Comments: