

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212683
Address: 1033 SW REDBUCK CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Tuesday, March 29, 2022

Corrective Action Required:

1	Misc	- Fire block penetration second floor toilet supply line and penetration - Adress I-beam 2" out of pocket north side basement 3/29/22 nothing changed 2 x6 under I-beam in basement need's to be cut square with beam to distribute the load and anchored to wall with anchor bolts at top middle and bottom OK to insulate
---	------	---

Comments: