

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213583

Address: 3825 SW WALSH DR, LEES SUMMIT, MO 64082 3823 SW WALSH DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Patrick Schonfeldt	Not Ready	Tuesday, March 29, 2022

Corrective Action Required:

1	Misc	3823 - GAS PRESSURE 0 PSI, MUST MAINTAIN 10 PSI FOR TEST
		3825 - PRESSURE OK

Comments: