

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20215387

Address: 914 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081932 NW BLACK TWIG CIR, LEES SUMMIT, MO  
64081900 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Vacuum</b>	Ronald Paynter	Passed	Tuesday, March 29, 2022

Informational:

1 Misc manhole C-1 failed, but manhole C-2 passed testing. RP 3-2-22

Corrective Action Required:

2 Misc Manhole C-1 failed it's vacuum test again. RP 3-25-22

Informational:

3 Misc Manhole C-1 passed vacuum testing. RP 3-29-22

**Comments:**