CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213813

Address: 3825 SW MARYVILLE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Patrick Schonfeldt Failed Tuesday, March 29,

Residential 2022

Corrective Action Required:

1 Misc -install all missing windows

-CS-PF bracing design at master bedroom windows, nail exterior sheathing

per design

-Land wiring to boxes at covered deck

-top plate to top plate corner connection at front entry wall

-rear south and north corners at daylight wall in basement, bottom plate and

(3) studs at corner nailed 12" oc together

Comments: