

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSITE20215386  
Address: 2200 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Vacuum</b>	Ronald Paynter	Failed	Tuesday, March 29, 2022

Informational:		
1	Misc	Manholes A-3 and A-4 passed their vacuum testing, while manholes A-5 and A-6 failed testing. RP 3-2-22
Corrective Action Required:		
2	Misc	Manhole A-5 failed it's vacuum test again. We didn't try manholes A-1, A-2 or A-6 yet. RP 3-25-22
Corrective Action Required:		
3	Misc	Manholes A-2 and A-6 passed, but manholes A-1 and A-5 failed vacuum testing. RP 3-29-22

**Comments:**