

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212634
Address: 3205 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Mitchell Schwarz	Failed	Wednesday, March 30, 2022

Corrective Action Required:
2 Misc GRAVEL FILTER BACK IN COMPLIANCE
Mitchell Schwarz 03/30/2022 8:52 AM

Corrective Action Required:
3 Misc clean gravel from street/curb
address erosion control straw wattle not working effectively

Comments: