

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20213082  
Address: 4729 NE SARATOGA CT, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Wednesday, March 30, 2022

Corrective Action Required:

1	Misc	-Install front door per security code
		-Provide CS-PF walls at breakfast per plan **Plan shows CSPF walls with min double 2x12 header spanning wall corner to corner
		**Or get engineer of the plan to address
		**OK TO INSULATE
		**PLEASE SUBMIT APEX ENGINEER LETTER ADDRESSING SUSPENDED SLAB INSPECTION ISSUES (MISSING PAD AND I BEAM)

Comments: