

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212068
Address: 3213 SW MARY ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Shawn Hoffman	Failed	Wednesday, March 30, 2022

Corrective Action Required:

1	Misc	Remove lumber and debris on silt fence at front of lot Repair silt fence No further inspections until corrections are made
---	------	--

Comments: