CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20213013 2613 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082 Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, March 30, 2022
Corrective Action Required:			

Corrective Action Required:

-seal all top and bottom plate penetrations though out(bed 4, master bath 1 Misc linen, front entry) -PFG remove siding to inspect nail pattern nail pattern -fire block top of furr out wall to furr down in garage -strap top plate lapped less than 24" left of window above front door

Comments: