

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191614
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Wednesday, March 30, 2022

Corrective Action Required:

1	Miscellaneous Correction	-COMPLETE CORRECTIONS FOR ALL OTHER DEPARTMENTS -OBTAIN FINAL HEALTH DEPARTMENT APPROVAL AT MC KITCHEN (DISHWASHER) -COMPLETE SITE ELECTRICAL AT FLAG POLE, MONUMENT SIGN -PROVIDE AFCI PROTECTION THROUGHOUT PER ARTICLE 210.12- UNIT KITCHENS
---	--------------------------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Corrective Action Required:

2	THE FOLLOWING AREAS ARE APPROVED	All residential units and common spaces in buildings A,B and C, and kitchen 164 approved for Occupancy **Memory Care and Assisted Living building approved for furniture only
---	----------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: