

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211947
Address: 4416 SW ALABASTER CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------------|----------|---------------------------|
| All Rough Inspection - Residential | Patrick Schonfeldt | Failed | Wednesday, March 30, 2022 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -CS-PF portal bracing design at dining room windows and dining room sliding glass door per plans, nail exterior sheathing per plans/IRC R602.10.6.4 -Fireblock deadspace front bedroom, solid fireblock, that loose insulation is not packed right enough and will fall with a space that large -fireblock vertical to horizontal at furred down soffit ends |
|---|------|--|

Comments: