

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204351
Address: 2529 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, March 30, 2022

Corrective Action Required:

1	Miscellaneous Correction	-provide strapping per plans for beam -hearth room windows need to be framed per 3/S505 have engineer address this -provide outlets per code at hearth room wall
---	--------------------------	--

-OKAY TO INSULATE DO NOT COVER ITEMS STILL NEEDING INSPECTION

Comments: