CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRCOM20191614Address:1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | | Inspector: | Outcome: | Date: |
|---------------------------|-------------------------|---------------------------------------|----------|-----------------------------|
| Rated Assembly Inspection | | Robb Popp | Passed | Thursday, March 31, 2022 |
| Informat 1 | ional: THIRD FLOOR | -AREAS APPROVED- | | |
| | tional: SECOND FLOOR | BUILDING C COMPLETE | | |
| | | BUILDING B COMPLETE | | |
| Informat | | BUILDING A COMPLETE EXCEPT ELEVA | TOR | |
| 2 | | -AREAS APPROVED- | | |
| | | BUILDING C: COMPLETE | | |
| | | BUILDING B: COMPLETE | | |
| | | BUILDING A: COMPLETE EXCEPT AT ELE | VATOR | |

| Informational: | | | | | |
|----------------|----------------------------------|---|--|--|--|
| 3 | FIRST FLOOR | -AREAS APPROVED- | | | |
| | | ***BUILDING C*** COMPLETE | | | |
| | | ***BUILDING B*** COMPLETE | | | |
| | | ***BUILDING A*** COMPLETE | | | |
| | | ****MCAL BUILDING*** COMPLETE EXCEPT AS NOTED: | | | |
| | | -165- RC OK | | | |
| | | -164- COMPLETE RATED LAYER AT DISHWASHER HOOD, RC OK | | | |
| | e Action Required: | | | | |
| 4 | Miscellaneous | -COMPLETE SCREW PATTERN AND SEAL GAPS AND PENETRATIONS AT | | | |
| Correctiv | Correction e Action Required: | MECHANICAL ROOM 165 | | | |
| 5 | ELEVATOR 1 | -FUR OUT WALLS OK | | | |
| | | -RC AT CEILING OK | | | |
| | | -RATED LAYER AT CEILING OK | | | |

Comments: