

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191614
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Passed	Thursday, March 31, 2022

Informational:
1 Misc Kitchen ok for skirts at dishwasher and hood
Memory Care corridors approved except as noted, room 21,22,25 approved corridor 167

Corrective Action Required:
2 Misc KITCHEN AREA:--NEED TO VERIFY ACCESS PANELS, OK FOR TILE
MC AREA: CORRIDOR 34,39 DAMPERS,

Comments: