

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20214977  
Address: 618 SW 3RD ST, Unit:A, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Michael Harkins	Failed	Thursday, March 31, 2022

Corrective Action Required:

1	Miscellaneous Correction	No city stamped plans on site Plan wall type legend call out 25 gauge metal studs to underside gypsum board at bottom of roof trusses Fire caulk all upward penetrations Provide midpoint support vertical dwv 2" & smaller Land mc cable in a box
---	-----------------------------	--

**Comments:**