



Aegis Fire Protection, Corporate: 11936 W. 119th St. #262 Overland Park, Is Phone: 913-825-0343 Fax: 913-322-4475 Email: info@aegisfirepro.com

3/30/22





	INL ALANWI LLGL	שוו.	WINING LEGEND
SYMBOL	DESCRIPTION	MOUNTING	18-2 FPLP WIRE (DATA)
NAC	N.A.C. POWER EXTENDER	WALL	10-E FFEF WIRE (DATA)
(2)	AREA SMOKE DETECTOR	CEIL./WALL	14-2 FPLP WIRE (A/V)
•	FIRE ALARM MANUAL STATION	WALL	
(B)(1	COMB. F.A. HORN & VISUAL SIGNAL	CEILING	
(((((((((((((F.A. VISUAL SIGNAL	CEILING	CENEDAL NOTES
	END OF LINE RESISTOR		GENERAL NOTES
			 1. ALL STROBES HAVE A 15 CANDELLA RATING UNLESS NOTED OTHERWISE. 2. CONNECT DATA/NAC WIRE TO EXISTING FIRE DEVICES AS SHOWN. 3. RELOCATE E.O.L. RESISTOR FROM EXISTING DEVICE TO NEW DEVICE AS SHOWN.



