



March 31, 2022

**Joe Frogge**

Plans Examiner  
City of Lee's Summit  
220 SE Green Street  
Lee's Summit, MO 64063

RE: Project Title: Oatman Family Dentistry  
Project Address: 700 NE LANGSFORD RD, LEES SUMMIT, MO 64063

Dear Mr. Frogge,

The following is information as requested by your inspector in reference to our drawings dated 9-22-21.

1. Contractor option to use wood studs in lieu of metal studs.
2. Contractor option for walls to terminate at the bottom of the lay in ceiling at Contractors option
3. Contractor option to use ½" sheetrock in lieu of 5/8".
4. Contractor option to put sheetrock on one side of wall in lieu of both sides.

If you have any questions in refence to these comments please call/email.

Best Regards,  
GUY GRONBERG ARCHITECTS, P.C.

GUY!

Guy Gronberg, AIA  
Architect