

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212568
Address: 3061 NW THOREAU LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Friday, April 01, 2022

Corrective Action Required:

1	Miscellaneous Correction	- No sliding door main floor - Nail all exterior intersecting corners to code 2 nails at 12" oc -- - -Gap in top plate master shower (now needs strap) - -Provide window front middle bedroom
---	--------------------------	---

3/30/22

New items

- fire block plenum space at study/ living room chase
- Fire block HVAC chase at atrium
- Fire block end of chase east bathroom top

Comments: