

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213493
Address: 3204 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Friday, April 01, 2022

Corrective Action Required:

1	Misc	-fire block dwv into hvac chase at pantry -address over notched joist above bath 3 -fire block behind bath 1 shower SEAL GAPS -fire block stairwell to garage wall (staircase to basement)
---	------	---

Comments: