

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211236
Address: 2163 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Ronald Paynter	Passed	Friday, April 01, 2022

Informational:	
1 Misc	Forms were placed and aggregate was present and compacted. Needed some more aggregate next to the driveway. Contractor dug it out and added extra aggregate. RP 3-21-22

Informational:	
2 Misc	Finished sidewalk meets LS and ADA specs. RP 4-1-22

Comments: