

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212317  
Address: 2113 NW ASHURST DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Ronald Paynter	Passed	Friday, April 01, 2022

Informational:	
1 Misc	Forms were placed and aggregate was present and compacted. RP 3-24-22
Informational:	
2 Misc	Finished driveway meets LS and ADA specs. RP 4-1-22

**Comments:**