

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRSUBD20212196
Address: 1630 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Sediment Control (ESC) Inspection	Adam Nacke	Failed - Stop Work	Friday, April 01, 2022

Corrective Action Required

1	Miscellaneous Correction	1-20-22 AN. Dirt needs to be cleaned off the street and curb line also Small section of silt fence needs to be repaired
---	--------------------------	---

Corrective Action Required

2	Misc	2-1-22 AN Welch was out here putting up more silt fence but the streets and curbs still need to be cleaned up
---	------	---

Informational

3	Misc	2-9-22 AN Holthouse has someone with a shovel cleaning up the curbs
---	------	---

Informational

4	Misc	2-10-22 AN. Holthouse has a bobcat with a sweeper cleaning the streets
---	------	--

Corrective Action Required

5	Miscellaneous Correction	3-22-22 AN 7th & 8th plat, need to get some more silt fence put up and get the dirt cleaned up off the street and clean front of storm boxes
---	--------------------------	--

Corrective Action Required

6	Miscellaneous Correction	3-30-22 AN emailed Holthouse about silt in roadway. Needs to
---	--------------------------	--

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

get cleaned up and a lot more silt fence

Corrective Action Required

7 Miscellaneous Correction 3-31-22 AN silt fence down on the perimeter of the south side.
Also as I said before you need to get a lot more silt fence up
ASAP! A large amount of silt is getting into the roads and the
storm boxes. Both 7th and 8th plat

Corrective Action Required

8 Miscellaneous Correction 4-1-22 AN. Had Kara Taylor come out to see the erosion issues
and we did a stop work order

Comments: