

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213109

Address: 3723 SW WALSH DR, LEES SUMMIT, MO 640823725 SW WALSH DR, LEES SUMMIT, MO 640823727
SW WALSH DR, LEES SUMMIT, MO 640823721 SW WALSH DR, LEES SUMMIT, MO
64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Friday, April 01, 2022

Corrective Action Required:

1 Misc

UNIT 3721: OK

UNIT 3723:

-repair damaged fire rock 2nd floor

UNIT 3725:

-repair damaged fire rock

-C channel guide required at fire rock to roof deck, see page A7.0, remove blocking to allow for inspection

UNIT 3727: OK

****OK TO INSULATE****

Comments: