

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210103
Address: 2100 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Friday, April 01, 2022

Corrective Action Required:

1	Misc	-Approval required from: Fire, Water, Planning, Field Engineering
		-Install roof access ladder per plan. **Ladder installation is very flimsy. Install the safety post to the side of ladder per plan. Ladder not installed per plan, sheet A2.3
		-RTU3 breaker shall be no more than 25 amp. Currently, 30 amp breaker is installed

Comments: