

FIRE DEPARTMENT

			NOTIFIC	ATIONS/CC	DNIACI INFORMA	ПО	N SECTION			
PAGE 1										
☐ CHANGES										
BUSINESS NAME	LEE'S SUMMIT SALES AND DETAIL CENTER									
ADDRESS	2100 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064									
OWNER/OPERATOR NAMI	ROTHWELL CONSTRUCTION INC: TELEPHONE (816)				(816) 228-8808					
ADDRESS	1500 NORTH BLUE SPRIN Primary: (816 Cell: (816) 20									
		EMERGENC	Y CONTAC	CT INFORM	IATION					
NAME	TELEPHONE									
1										
2.										
3.										
4.										
		LOS	S REDUCT	ION TYPE						
☐ Occupancy ☐ Se	emi-Annual	☐ Annual	☐ Life S	afety	Sprinkler		Hazardous Material Permit			
☐ Complaint ☐ Ex	plosive Storage	☐ UST	☐ Post-I	ncident	☐ Open Burning		Other			
CLASS: S-1	Мар#:	PFA#:	KNOX BO	X:	KNOX LOCATION:		PERMIT #			
10-1		LOSS R	EDUCTION	I NARRATI	VE					
	□ NO VIOLATIONS NOTED □ ALL VIOLATIONS RESOLVED									
Last Inspection 1st Inspection				rd Inspection						
		ECTOR		OUTCOME Passed	DATE Friday Jo	Friday, January 21, 2022				
Sprinkler - Hydrostatic Test		ווורו א		rasseu	riiday, Ja	ıııua	ıı y ∠ I, ∠∪∠∠			
Alarm Test	Alarm Test Ben			Passed	Wedneso	Wednesday, March 23, 2022				
Sprinkler - Flow Test Ben		n Hicks		Passed	Thursday	Thursday, March 24, 2022				

	top button by FDC	Temporary C of O	Monda	ay, March 28, 2022				
Occupancy Inspection - Fire Ben Hicks Passed Friday, April 01, 2022 Corrective Action Required: 1 Label emergency stop button by FDC Label water tank for car wash Add exterior emergency illumination at front door Detail bay southwest exterior emergency illumination out and exit sign.								
DATE OF REPORT	INSPECTOR	PREVENTION FOLLOW-UI REQUIRED?	Р	RESPONSIBLE SIGNATURE				
April 01, 2022	Ben Hicks	☐ Yes ☐ No						