

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20211647
Address: 250 NW MCNARY CT, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Michael Harkins	Partial	Monday, April 04, 2022

Corrective Action Required:		
1	Miscellaneous Correction	COMPLETE ISOLATION ROOM EXHAUST FAN TO ROOF, OK TO DROP CEILING TILE ALL OTHER AREAS

Comments: