

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213827
Address: 4709 NE FREEHOLD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Passed	Monday, April 04, 2022

Corrective Action Required:

1	Misc	-Connect ducting to all bath fans -Provide fall protection for bedroom windows -Fb wall plate penetration by dryer duct -At rear master bedroom wall, strap top plates and protect plumbing -Protect plumbing at master toilet wall top plate -Nail siding at roof flashing at left master closet wall -Strap across cut top plates at front bedroom gable wall -Protect plumbing at wet bar -Nail joist hanger above basement bottom stair landing -Blocking cantilevered joists over wall
---	------	--

**OK TO INSULATE

Comments: