

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20216100
Address: 4813 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Khanh Nguyen	Failed - Stop Work	Monday, April 04, 2022

Corrective Action Required

1	Miscellaneous Correction	4-1-22 AN silt fence needs to be repaired and silt in road way needs to be cleaned up immediately. This spot always seems to be a issue.
---	--------------------------	--

Corrective Action Required

2	DCM6 ESC INSP DENIED STREET CLEAN UP	STREET CLEAN UP REQUIRED IMMEDIATELY. THE BUILDER WAS CALLED LAST WEEK 3/31/22 ABOUT THE EROSION CONTROL FAILURE AND SIGNIFICANT AMOUNT OF SILT FLOWING ONTO THE STREET. TODAY (4/4/22), THE EROSION CONTROL HAS NOT BEEN REPAIRED AND STREET HAS NOT BEEN CLEANED UP. PERMIT IS PUT IN STOP-WORK ORDER UNTIL EROSION CONTROL IS IN COMPLIANCE
---	---	--

Comments: