

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211947
Address: 4416 SW ALABASTER CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Monday, April 04, 2022

Corrective Action Required:

1	Misc	-CS-PF portal bracing design at dining room windows and dining room sliding glass door per plans, nail exterior sheathing per plans/IRC R602.10.6.4, check the nailing, remove trim can't see nail pattern
		-fireblock vertical to horizontal at furred down soffit ends, see the south end of furred down soffit that runs along the den, the furred down is open to the wall beside it and needs to be fireblocked, this is furred down I pointed out to you during 1st inspection

Comments: