

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212204
Address: 4736 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Monday, April 04, 2022

Corrective Action Required:

1	Misc	-Fb master toilet wall from roof; wall at master bedroom door
		-Fb dead space at basement bathroom tub; Fb wall from joist space at bedroom 4
		-Cannot use laundry drain to vent basement bathroom sink **protect plumbing

**OK TO INSULATE

Comments: