

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212204  
Address: 4736 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection</b>	Khanh Nguyen	Failed	Monday, April 04, 2022

Corrective Action Required:

1	Misc	-Ground service to ufer rebar with listed clamp for aluminum conductor. Use the listed aluminum clamp and flip the bottom half around for tight connection to rebar **The current clamp appears to be a Greaves GR-DB rebar clamp listed for copper conductor only. Provide info for the clamp
---	------	---

**Comments:**