

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215300
Address: 500 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Failed	Monday, April 04, 2022

Corrective Action Required:

1	Miscellaneous Correction	Complete vent to roof near front window Fire caulk upward penetrations Seal gaps in fire blocking Provide vertical fire blocking every 10' at furr out areas Complete roof drains at outside dining area
---	-----------------------------	--

Comments: