

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20214283  
Address: 1808 SW SAGE CANYON RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Service Inspection - Residential</b>	Patrick Schonfeldt	Failed	Tuesday, April 05, 2022

Corrective Action Required:

1	Misc	-GAS PRESSURE AT 0 PSI ,MUST MAINTAIN 10 PSI FOR TEST
		-GAS LINE BOND REQUIRED

**Comments:**