

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213536
Address: 2353 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, April 05, 2022

Corrective Action Required:

1	Misc	-seal bottom plate in penetration for thermostat -plans call for double lvl closest to back sliding door. -remove coving for covered patio for inspection -sill plate in basement anchor bolts to be in the middle 1/3 of plate and tight though out basement -fire block for DWV above bed 4 window -bed 4 closet seal around dwv going through fire blocking -outlet required within 25' of A/c unit
---	------	--

Comments: