

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211710
Address: 2345 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Tuesday, April 05, 2022

Corrective Action Required:

1 Misc

- No further inspections until Eros control is in compliance
- sod
- address siding from ground at back of lot
- Address to be of contrasting colors
- seat top of A/c disconnect and all other exterior penetrations
- splash blocks and sump pump discharge to extend 36" from foundation
- security screws at back doors
- jet tub pump to be accessible to code
- sheet off set screw for anti syphon device at water
- remove rebar from street
- driveway inspection still pending

Comments: