

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20211738
Address: 2061 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Failed	Tuesday, April 05, 2022

Corrective Action Required:

1	Misc	-Approval required from: Fire, Field Service Engineer, Planning, Water, Jackson County Health -Install restroom signage -All receptacles in kitchen area must be gfci-protected per NEC 210.8(B) (BREAD WARMER) -Return ramp handrail to wall or floor patio -Complete vestibule 101; all seatings in dining areas -Provide performance test report for kitchen hood system as required per IMC 507.6. Smoke test will be performed when ready
---	------	---

**OK FOR STOCKING AND TRAINING

Comments: