CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRSUBD20214758Address:1270 SE BROADWAY CIR, LEES SUMMIT, MO 640811300 SE RANSON RD, LEES SUMMIT, MO
640811001 SE BAILEY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Storm Sewer Construction Inspection		Inspector: Tom Taylor	Outcome: Partial	Date: Tuesday, April 05, 2022
1	Misc	On Tuesday, 4-05-2022, The Amino Brothers Construction Co. installed CI box E-1 at the east end of the entrance. It was found the honch that was designed to go around the sides of the box came without them. The contractor was notified and I will ask for the solution from an engineer. The contractor also completed demo of the curbs along the front of school.		

Comments: