

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213323

Address: 3813 SW WALSH DR, LEES SUMMIT, MO 640823811 SW WALSH DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Patrick Schonfeldt	Failed	Tuesday, April 05, 2022

Corrective Action Required:

1 Misc

UNIT 3811:

- fire rated plywood required within 4' of firewall -see garage
- repair any damaged sections of fire rock
- Fire caulk fire wall penetrations by SE cable at basement, Refer to A7.1 for detail

UNIT 3813:

- fire rated plywood required within 4' of firewall - see garage
- repair any damaged sections of fire rock
- Fire caulk fire wall penetrations by SE cable at basement, Refer to A7.1 for detail

Comments: