

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220280
Address: 1752 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Michael Harkins	Partial	Wednesday, April 06, 2022

Corrective Action Required:

1	Misc	PARTIAL PASS SCREW PATTERN APPROVED FOR TAPE DIMISING WALL REPAIR DRYWALL CUT 18" FROM FLOOR REPAIR DRYWALL AT DOOR OPENING PASSING THROUGH NEAR RESTROOMS FIRE CAULK ALL PENETRATIONS & ROOF DECK
---	------	--

Comments: