

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214591
Address: 1103 SW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Surface	Ronald Paynter	Partial	Wednesday, April 06, 2022

Informational:		
1	Misc	Hanrahan Asphalt laid down 127 tons 4 inches thick of APWA Type 5 R for the base layer. RP 12-22-21
Informational:		
2	Misc	Dakota's crew from Hanrahan laid 75 tons of APWA Type 3 R for the parking lot surface. RP 4-5-22

Comments: