

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212477
Address: 1515 SW ARBOR VALLEY DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Wednesday, April 06, 2022

Corrective Action Required:

1	Misc	-final grade and sod -complete pending sidewalk inspection -address to be properly illuminated -splash blocks and sump pump discharge to extend 36" from foundation -Seal top of meter can, A/c disconnect and all other exterior penetrations. -guard rail where required at front stoop -spark rings required at kitchen backsplash outlets -label all non GFCI outlets in unfinished spaces -(2) 1/2" though bolts at each deck post to beam connection
---	------	--

Comments: