CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213121

Address: 3105 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

All Rough Inspection - Mitchell Schwarz Failed Wednesday, April 06,

Residential 2022

Corrective Action Required:

1 Misc -fire block for radon at rear garage wall to attic space

-protect NM with in 6' of attic access
 -add studs per plans at rear sliding door
 - lateral bracing for truss per plans
 -support ridge beam at front stoop

-sold block under kitchen island per plans

-install all garage doors and doors

Comments: