

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213631
Address: 425 NW KAYLEA CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Michael Harkins	Failed	Wednesday, April 06, 2022

Corrective Action Required:	
1 Miscellaneous Correction	CONNECT GAS LINE TO FIREPLACE SHIELD GAS LINE AT FIREPLACE SECURE GAS LINE AT FIREPLACE PROVIDE MIN 10 PSI FOR 15 MIN

Comments: