

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20215423  
Address: 2026 SW HOOK FARM DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Wednesday, April 06, 2022

Corrective Action Required:

1	Misc	<ul style="list-style-type: none"><li>-nail all intersecting wall corners 12" OC</li><li>-seal hole in floor Along west wall kitchen area</li><li>-land electrical at back deck area</li><li>-protect NM at kitchen east wall</li><li>-Fire block dead space at laundry</li><li>-protect NM With in 6' of attic access</li><li>-complete bath fan exhausts in master bathroom</li><li>-Provide engineer address for non-continuous studs at gable wall of living room</li><li>-have engineer address walls taller than 12' must be a minimum 2x6</li><li>-add support for stair entry landing and basement wall double joist</li><li>-install all windows and doors</li><li>-complete water lines at NW corner garage</li><li>-secure water line in mechanical room</li><li>-panning for RA in furr down above furnace not complete</li><li>-complete basement bath exhaust</li><li>-seal around block above bed 4 entry stud bay used to close off joist spaces used for return air</li><li>-seal penetrations into soffit above service panel</li><li>-connect the ufer ground to the middle grounded bus bar</li><li>-solid block sheathing break in Rec room S wall</li></ul>
---	------	---

Corrective Action Required:	-nail off joist hanger near bed 4 in Rec room
2            Misc	Provide access to front stoop for entry, for inspection.

**Comments:**